

From: [Bresnahan, Meaghan](#)
To: [R6HarveyInfo](#)
Subject: FW: Call 8/29/17
Date: Friday, September 1, 2017 7:29:13 AM

M6H1 – Harvey Response

From: Mistry, Jatin
Sent: Tuesday, August 29, 2017 1:06 PM
To: Jackson Langley <waterworks@actribe.org>
Cc: Bresnahan, Meaghan <bresnahan.meaghan@epa.gov>; Moreno, Miguel <Moreno.Miguel@epa.gov>
Subject: RE: Call 8/29/17

Hi Jackson,

I hope you and your family are keeping well and are in a safe location from the floodwaters.

Meghan did pass along the update from the system and please let us know if you lose power or pressure drops below 20 PSI such that the appropriate boil water notifications can be issued.

I have updated your due dates for the following significant deficiencies from August 31 to September 29, 2017. Your new due items are below:

Alabama Coushatta Westside

Item #1 Due on September 29, 2017 No back flow preventer device for backwashing greensand filter. Due date extended due to Hurricane Harvey.
Item #3 Due on September 29, 2017 Properly abandon or develop test well. On August 8, EPA was informed that the test well is abandoned and photos will be sent. Due date extended

due to Hurricane Harvey.

Item #8 Due on September 29, 2017 Inspect and clean elevated storage tank. On August 8, EPA was informed that the inspections and cleanings are complete

and report will be sent. Due date extended due to Hurricane Harvey.

Alabama Coushatta Eastside

Item #3 Due on September 29, 2017 No back flow preventer device for backwashing greensand filter. Due date extended due to Hurricane Harvey.
Item #10 Due on September 29, 2017 Inspect and clean Tank #1, Tank #2, and pneumatic tank. On August 8, EPA was informed that the inspections and cleanings report will be sent. Due date extended due to Hurricane Harvey.

Thank you,
Jatin

Jatin H. Mistry
US EPA Region 6
Drinking Water Section
1445 Ross Avenue (6WQ-SD)
Dallas, TX 75202
(Voice) 214-665-7483
(Fax) 214-665-2191
mistry.jatin@epa.gov

From: Bresnahan, Meaghan
Sent: Tuesday, August 29, 2017 7:52 AM
To: Mistry, Jatin <Mistry.Jatin@epa.gov>
Cc: Jackson Langley <waterworks@actribe.org>; Moreno, Miguel <Moreno.Miguel@epa.gov>
Subject: Call 8/29/17

Hi Jatin,

I talked to Jackson early this morning to follow up on hurricane response. He mentioned that he'd like to extend the schedule for any remaining significant deficiencies (ie backflow preventer) to 9/30. The contractor coming out to work on it had to postpone his trip due to the hurricane. Please follow up with Jackson and/or Miguel if necessary.

Miguel, if Jatin approves the new schedule, would you please make the change in the tracker?

Thanks,
Meaghan

Meaghan Bresnahan
Drinking Water Section
EPA Region 6
1445 Ross Ave (6WQ-SD)
Dallas, TX 75206
(214)665-8354